



**Minnesota State Capitol  
Repairs, Restoration, &  
Preservation**  
75 Rev Dr. Martin Luther King Jr Blvd  
Saint Paul, MN 55155  
SCB-02CB0015

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

G. THE ELECTRICAL DRAWINGS SHOW ALL EXISTING ELECTRICAL EQUIPMENT AND SYSTEMS AS CAN BE VIEWED OR AS INDICATED ON PREVIOUS CONTRACT DOCUMENTS AVAILABLE. THE CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS TO DETERMINE THE ENTIRE EXTENT OF EXISTING ELECTRICAL SYSTEM EQUIPMENT AND CONTROLS. THESE DRAWINGS SHOW DEMOLITION WORK THAT WILL BE COMPLETED IN TOTAL FOR ALL CONSTRUCTION PHASES, NOT JUST FOR THIS WP-1 SCOPE OF WORK. THIS CONTRACTOR SHALL LEAVE ALL EXISTING ELECTRICAL SYSTEM EQUIPMENT AND CONTROLS THAT ARE NECESSARY TO SERVE THE OCCUPIED BUILDING AREAS DURING WP-1, REMOVING ONLY THAT WHICH IS NECESSARY FOR WP-1 DEMOLITION.

KEYNOTES:  
1. NOT USED.

1 TERRACE LEVEL LIGHTING DEMOLITION PLAN  
1/16" = 1'-0"